



राज्य भार प्रेषण केन्द्र

STATE LOAD DISPATCH CENTRE

**WEEKLY REACTIVE ENERGY ACCOUNT**

**UNDER INTRA STATE ABT**

**Period From 05 March- 2007 to 11 March-2007.**

**Week No : 50**

**Contents**

**Covering Letter**

**REC Summary**

**Details of REC Account**

**TRIAL BILL UNDER ABT**



ગુજરાત એનર્જી ટ્રાન્સમીસન કોર્પોરેશન લિમિટેડ

**GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED**

રાજ્ય ભાર પેષણ કેન્દ્ર

**STATE LOAD DESPATCH CENTRE**

Email : sldcabt@gebmail.com

Tel:- 0265 - 2352103, 6531132, 2322210 Fax 0265- 2322204

Ref No: SLDC/ABTSEC/week 50/2007/3.2

Date : 15-04-2007

**Trial bill for Mock Exercise of ABT**

To ;

- |  |   |
|--|---|
| 1) General Manager (Commerce), UGVCL, Mehsana    | 2) Managing Director, UGVCL, Mehsana.   |
| 3) General Manager (Commerce), DGVCL, Surat      | 4) Managing Director, DGVCL, Surat      |
| 5) General Manager (Commerce), MGVCL, Vadodara   | 6) Managing Director, MGVCL, Vadodara   |
| 7) General Manager (Commerce), PGVCL, Rajkot.    | 8) Managing Director, PGVCL, Rajkot.    |
| 9) General Manager ( Finance), GETCO, Vadodara.  | 10) Managing Director, GETCO, Vadodara. |
| 11) General Manager (commerce), GUVNL, Vadodara. | 12) Chief Engineer, GUVNL, Vadodara.    |
| 13) Chief Manager ( Finance), TAECO, A'dabad.    | 14) General Manager, TPEACo, A'dabad    |
| 15) Chief Manager ( Finance), SECO, Surat        | 16) General Manager, SEACo, Surat       |
| 17) Manager(Account) , KPTL, Kandla.             | 18) Chief Manager, KPTL, Kandla.        |
| 19) Member Secretary ,GERC, Ahmedabad            |   |

Sub : Reactive Energy Charges(REC) Account for the week from **05.03.07** to **11.03.07**..

Sir,

The statement of account of Reactive Energy Charges for State grid utilities from **05.03.07** to **11.03.07** under Intra state ABT is enclosed herewith. A utilities who have to pay reactive charges are requested to make payments to the pool accounts within 07 days from the date of statement issued( as per clause 16(i) of GERC order no.03/11<sup>th</sup> Augsut-06). Payments received after 08 days shall attract simple interest @ 0.04% interest for each day of delay.

Details of reactive energy account for the above week is available at SLDC website [www.sldcguj.com](http://www.sldcguj.com) under commercial link & sub link weekly REC account. **(Due date for payment on or before : 22.04.07 )**

Yours faithfully

Chief Engineer ( LD )

Encl:

- (1) REC Summary Statement
- (2) Detail statement of REC for individual utility.

राज्य भार प्रेषण केन्द्र

**STATE LOAD DISPATCH CENTRE**

Vadodara -390002, Website : www.sldcguj.com

No. SLDC / ABT /Comm / Week 50/3.2

Date :

15-Apr-07

**Summary of Reactive Energy Charges of constituents with ISTS**

for the week from **05-March-07** to **11-March-07**

	PGVCL	DGVCL	UGVCL	MGVCL	GUVNL			Total
					TPAECo.	TPSECo.	KPTL.	
High Voltage (>103%)	144291.60	-87022.20	542813.56	938914.87	-371316.15	-55409.70	50.85	<b>1112322.83</b>
Low Voltage (< 97% )	-49942.20	180698.80	-14771.25	6979.50	0.00	-4504.50	0.45	<b>118460.80</b>
<b>Total</b>	<b>94349.40</b>	<b>93676.60</b>	<b>528042.31</b>	<b>945894.37</b>	<b>-371316.15</b>	<b>-59914.20</b>	<b>51.30</b>	<b>1230783.63</b>

**Note :-**

1. VARh Charges are Rs. 50.00 per MVARh . It is as per GERC order no.03 dated 11th August-06.
2. Positive figures payable to REC Pool Account and Negative figures receivable from REC Pool Account.
3. Any discrepancies in the calculations may be informed at the earliest.
4. All reactive energy transactions are considered with the GETCO network. Hence amount payable to REC pool account is to be receivables/ payable to/from GETCOs account.
5. Reactive energy calculations made for all interconnecting lines between interdiscom as well as GUVNL( licensees TPAECo, TPSECo, KPTL) as per the allocation given by GUVNL vide no. GUVNL/COA/929 dt 14/06/06.
6. Presently all interconnecting lines of GETCO are considered between discom at notional boundaries. However, the EHV lines connected with ISTS considered as interconnecting lines between GETCO and ISTS. Reactive energy account for MVAR exchange among ISTS network shall be applicable as per REC account of WRLDC. No any exchange shall be considered with the network comprises under Discom boundary.
7. Reactive Drawl for KPTL is not derived, which is yet to configure as the verification of meter detail of KPTL is to be done.